
## 1c-7-1 Globe Valves



Production according to TR 2913-001-15365247-2004

Pipeline connection: welded connection.

**Installation position on the pipeline:** any position in the upper semi-sphere with regard to the neck. The valves (globe valves) are intended for outdoor installation and installation in closed premises.

**Working medium supply direction:** we recommend using of medium flow direction under the gate.

Gate sealability: according to class A GOST 9544-2015.

**Climatic version:** У, УХЛ, T according to GOST 15150-69.

**Placement category:** 1, 2, 3 according to GOST 15150-69.

Manual override force (handwheel, lever): not more than 300 N.

The valves DN10 – DN65 may be manufactured with an easily replaceable seat from titanium or nickel alloy upon the customer's demand.

# **Specifications**

DN, mm	PN, MPa	Tmax of the Mediu m, °C		Worki ng Me dium		TQ, N•m, maxi mum torqu e at s pindle plug	ζ, not more than	Full Strok e Rot ation Numb er	L, mm	Contr ol Met hod	H, mm	h, mm	D, mm	D1, mm	d, mm	Weigh t with out El ectric Actua tor, kg	Torqu e, N*m
80	6,3	425	25Л	Water- Stea m	72	290	6,4	12	380	М	550	460	81	93	320	52	0

#### Legend

P - Pressure

**DN** - Nominal Diameter **PN** - Nominal Pressure

Temperature

**Μκρ** - Spindle Torque

t - Response time

μ - Fluid Flow Coefficient

Tmax - Maximum Design

 $\boldsymbol{h}$  - Valve Stroke

Kv - Throughput Capability

**F** - Seat Area

ζ - Resistance Coefficient

The globe valves refer to the stop valves of two-position action.

They are only used for opening or blocking of pipelines by means of reciprocative movement of the shut-off device.

### The globe valve control is carried out with the help of:

a lever or handwheel (M);

🛚 a built-in electric actuator (E);

a universal ball joint (G);

a cylindrical reduction gear unit (Cy);

 $\ensuremath{\mathbb{Z}}$  a cone reduction gear unit (Cn).

The valve configuration is adapted to application of electric

#### actuators manufactured by the following companies:

- ∃ − Barnaul Boiler Plant, LLC; CHZEM, Chekhov;
- ☑ ЭГ GZ Elektroprivod, Moscow;
- № 94 ABS ZEIM Automation, OJSC, Cheboksary;
- ∃ ∃H − BETRO-Tech, Berdsk;
- 🛮 ЭM Tulaelektroprivod, Tula;
- 🛮 3K ZPA Pecky, Czechia;
- ∃Д AUMA, Germany;
- $\ensuremath{\mathbb{I}}$  other manufacturers with standard connection units.

The allowed values of operating pressures and temperatures for the fittings may differ from those ones given in the table with technical specifications and are chosen in accordance with GOST 356-80, provided that they shall not exceed the limits prescribed by the respective State Supervision Rules and Standards for these materials and operation conditions.

According to GOST 356-80, the items designed for the ultimate pressure allow their application on operating parameters within the following range:

- ${\tt M}$  at PN 10 MPa from 10 MPa, 200 °C to 3,6 MPa, 455 °C;
- $\ensuremath{\mathbb{I}}$  at PN 25 MPa from 25 MPa, 200 °C to 9 MPa, 455 °C;

## Page link:

https://en.bkzn.ru/catalog/armatura-zapornaya/klapany-zapornye/1c-7-1/