
## 827-150/250-O<sub>П</sub>



Production according to TR 3113-003-15365247-2009

Connection: welded connection.

Structural versions: various designs depending on

operating parameters of live

and reduced cooled steam. They differ from each other

in dimensions, injection unit

version and structure of atomizing devices, as well as in

the number of throttle grids.

Material of desuperheater bodies: steel of type

12X1MΦ, 15X1M1Φ.

## **Specifications**

DN, mm	Pp, MPa	T, °C	Work ing Medi um	L, mm	L1, mm	H, mm	D1, mm	D2, mm	D3, mm	D4, mm	D5, mm	D6, mm	Full Weig ht, kg	\$1, cm2	\$2, cm2	\$3, cm2	S4, cm2	S5, cm2	S6, cm2
150	4,1	545	Пар	1500	320	604	163	194	248	273	20	32	187	75	0	0	0	0	0

The steam desuperheaters are intended for steam cooling-down and form an integral part of DS, PRDS and FRPRDS. The steam is cooled-down in the desuperheater thanks to injection of cooling water or steam-water mixture.



The cooling water is injected with the help of atomizing devices (nozzles of mechanical and steam atomization, atomizing inserts or spraying jets), the flow through which is regulated with an injection valve. A signal for the flow control of cooling water is given at the temperature of the cooled steam in the pipeline behind the steam desuperheater. The steam desuperheaters may be equipped with one or several throttle grids which perform final steam reducing after the pressure reducing valve (for PRDS, FRPRDS).

The grids also serve as noise dampers simultaneously, while reducing the noise level during steam expansion in the desuperheater. Installation: on horizontal and vertical pipeline sections behind the steam reducing valve.

The table demonstrates typical steam desuperheaters. However, the majority of steam desuperheaters is individually designed for specific operation conditions.

## Page link:

https://en.bkzn.ru/catalog/rou-brou-ou-ru-oborudovanie/oxladiteli-na-vysokie-parametry-para/827-150250-op/